



Ernie Fletcher  
Governor

LaJuana S. Wilcher, Secretary  
Environmental and Public  
Protection Cabinet

Christopher L. Lilly  
Commissioner  
Department of Public Protection

Linda Neal  
Nebo Water District  
45 North Bernard Street  
P. O. Box 147  
Nebo, KY 42441

Commonwealth of Kentucky  
**Public Service Commission**  
211 Sower Blvd.  
P.O. Box 615  
Frankfort, Kentucky 40602-0615  
Telephone: (502) 564-3940  
Fax: (502) 564-3460  
psc.ky.gov

Mark David Goss  
Chairman

Teresa J. Hill  
Vice Chairman

Gregory Coker  
Commissioner

March 24, 2006

CERTIFICATE OF SERVICE

RE: Case No. 2006-00023  
Nebo Water District

I, Beth O'Donnell, Executive Director of the Public Service Commission, hereby certify that the enclosed attested copy of the Commission's Order in the above case was served upon the addressee by U.S. Mail on March 24, 2006.

Executive Director

BOD/sh  
Enclosure

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF NEBO WATER DISTRICT	)	CASE NO.
FOR A DEVIATION FROM THE REQUIREMENTS	)	2006-00023
OF 807 KAR 5:066, SECTION 4(4), REGARDING	)	
WATER STORAGE	)	

O R D E R

On January 17, 2006, the Nebo Water District ("Nebo District") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Nebo District states in its application that its average daily water usage, including unaccounted-for water, is approximately 421,000 gallons, and that its current water storage capacity is 375,000 gallons. The city of Madisonville ("Madisonville"), Nebo District's current water supplier, has agreed to supply up to 18,000,000 gallons of water per month. Madisonville has assured, by letter, the availability of water storage for all customers in the Nebo District.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Nebo District is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Nebo District should be given until January 17, 2011 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:


1. Nebo District is given until January 17, 2011 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Nebo District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 17, 2011.

Done at Frankfort, Kentucky, this 24th day of March, 2006.

By the Commission

ATTEST



Executive Director